



PO Box 437 MOUNT MARION, NY 12456 ~ 962 KINGS HIGHWAY, SAUGERTIES, NY 12477

PHONE (888) 528-7853 FAX (845) 246-2619

Website: www.nesolite.com



TO WHOM IT MAY CONCERN

DATE: June 30, 2017

The gradation, specific gravity and density of our minus 3/4" to #4 (343) is listed below. Northeast Solite Lightweight Aggregate meets the requirements for ASTM C-330.

Gradation:

<u>SIEVE</u>	<u>% Passing</u>	<u>ASTM C330 Specification</u>
1"	100	100
3/4" (19 mm)	100	90-100
1/2" (12.5 mm)	64	
3/8" (9.5 mm)	37	10-50
#4 (4.75 mm)	5	0-15

Specific Gravity : 1.45 (OD)
1.62 (@12%)

Density (OD): 47 pcf Max 55 pcf

If you have any further questions, please do not hesitate to contact me.

Ronald E. Vaughn
Director of Technical Services

cc: RV/file